


OFFICE OF THE DISTRICT MEDICAL AND HEALTH OFFICER,
MEDCHAL MALKAJGIRI DISTRICT.

Rc.No. 023 / SHP / DM&HO / Medchal / 2024 - 25. Dated: 02 / 04 / 2024.

SANITARY CERTIFICATE

I here by certified that Our Health Supervisor inspected the **M/s Niraj International School**, Located at H.No: 2-75/3, Sy.No: 132, 133, Kandlakoya Village, Medchal Mandal, Medchal-Malkajgiri District building and premises and certify that the accommodation provided for each of the several classes is sufficient for maximum number of pupils taught therein, and is properly ventilated and lighted, that the building is maintained in substantial repairs, is neat and clean, that the urinals & latrine arrangements are adequate and satisfactory and the supply of Safe drinking water is wholesome, and in all other necessary respects the Hygienic and sanitation is in good condition, for the Academic Year 2024- 25.

This certificate should be got renewed by the starting of every academic year by applying to the District Medical & Health Officer, Medchal District.


District Medical & Health Officer,
Dist. Medical & Health Officer,
Medchal Dist., Telangana



Microbiology Testing Laboratory
An ISO 9001:2015 Certified Company

Aleap Common Facilities Area,
Survey No. 342, Aleap Industrial Estate,
Near Pragathi Nagar, Opp. JNTU Lane,
Kukatpally, Hyderabad - 500 072.

Mobile : 98485 94359, 96666 91334

Website: www.mptari.com

E-mail : mptari@gmail.com, mptri@rediffmail.com

TEST REPORT

Issued to:
M/s. Niraj International School,
132,133, Kandlakoya (Vill), Medchal (Mdl),
R.R (DT), Hyderabad – 501 403.

Report No.: MPTRI/W/11516/4
Issue Date: 28th Mar, 2024
Customer Ref.: Nil
Ref. Date: 23rd Mar, 2024

Sample Particulars: Drinking Water

Qty.: 1 X 1000 ml. Type of Packing: Sterilized Bottles. Test Reqd.: Important Parameters.
Date of starting of analysis: 23rd Mar, 2024 Date of completion of analysis: 28th Mar, 2024

TEST RESULTS

Essential Characteristics	Units	Result	Desirable Limits as per IS:10500
Colour	Hazen, Max	<1.0	5.0
Odour		Agreeable	Agreeable
Taste		Agreeable	Agreeable
Turbidity	NTU, Max	<1.0	1.0
pH	--	6.83	6.50-8.50
Total Hardness (as CaCO ₃)	mg/l, Max	25	200
Iron (as Fe)	mg/l, Max	<0.01	0.3
Chloride (as Cl)	mg/l, Max	18.0	250
Residual Free Chlorine	mg/l, Min	<0.1	0.2
Fluoride (as F)	mg/l, Max	<0.1	1.00
Desirable Characteristics			
Dissolved Solids	mg/l, Max	62	500
Calcium (as Ca)	mg/l, Max	12.06	75
Magnesium (as Mg)	mg/l, Max	2.19	30
Copper (as Cu)	mg/l, Max	<0.01	0.05
Manganese (as Mn)	mg/l, Max	<0.01	0.1
Sulphate (as SO ₄)	mg/l, Max	0.89	200
Nitrate (as NO ₃)	mg/l, Max	<0.01	45
Alkalinity	mg/l, Max	20	200
Aluminum (as Al)	mg/l, Max	<0.01	0.03
Bacteriological Characteristics			
Coliforms/100ml	CFU	Absent	Absent
E.coli/100ml	CFU	Absent	Absent

Remarks: The above analyzed test results are within the Desirable limits as per IS: 10500-2012.


SWATHIN
AUTHORISED SIGNATORY

